CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2017-12-23-02 Date: 26/12/2017

Customer : Assistant Executive Engineer, Project division, BBMP, Bangalore.

Address : Project division, BBMP, Bangalore.

Project Name : Improvements to Hoysala Playground-Balance developmental works.

Agency : Sri. H.V. Onkarappa, #27, Taralabalu Enclave, near Police Station, Yelahanka, Bangalore-64.

Customer's Reference : EE(Project)/YnkZone/WO/84/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 23-12-2017

Sample ID No : 2017-12-23-02/02

Customer ID : M25 Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 26/12/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	M25 Concrete	M25	19/12/2017	26/12/2017	150.45 X 149.74 X 148.61	22528	8.241	412.3	18.3	18.0
2	M25 Concrete	M25	19/12/2017	26/12/2017	150.32 X 151.83 X 149.47	22823	8.196	406.3	17.8	
3	M25 Concrete	M25	19/12/2017	26/12/2017	150.75 X 151.43 X 150.66	22828	8.238	406.3	17.8	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Page 1 / 1
****End of Report****

CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 26/12/2017

Lab ID	:	CP-2017-12-23-02
Customer	:	Assistant Executive Engineer, Project division, BBMP, Bangalore.
Address	:	Project division, BBMP, Bangalore.
Project Name	:	Improvements to Hoysala Playground-Balance developmental works.
Agency	:	Sri. H.V. Onkarappa, #27, Taralabalu Enclave, near Police Station, Yelahanka, Bangalore-64.
Customer's Reference	:	EE(Project)/YnkZone/WO/84/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	23-12-2017
Sample ID No	:	2017-12-23-02/01
Customer ID	:	M25 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	26/12/2017

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	M25 Concrete	M25	19/12/2017	26/12/2017	150.22 X 150.44 X 150.45	22599	8.271	420.3	18.6	18.1
2	M25 Concrete	M25	19/12/2017	26/12/2017	150.32 X 150.54 X 150.35	22629	8.254	402.8	17.8	
3	M25 Concrete	M25	19/12/2017	26/12/2017	150.22 X 150.44 X 150.55	22599	8.212	404.5	17.9	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |